

CERTIFICATE OF COMPLIANCE

SN20 (Class 1000) Draincoil

Vinidex supplies and manufactures Draincoil to comply with the following requirements of **AS 2439.1 "Perforated plastics drainage and effluent pipe and fittings. Part 1: Perforated drainage pipe and associated fittings"**:

Clause	Requirement	Test method	Result
2.3	Freedom from defects	Visual inspection	Pass
2.4.1	Diameter	Appendix B	Pass
2.4.2	Length	Clause 2.4.2	Pass
5.2	Bending	Appendix C	Pass
5.3	Straightening	Appendix D	Pass
5.4	High temperature impact resistance	Appendix E	Pass
5.5	Low temperature impact resistance	Appendix F	Pass
5.6	Elongation	Appendix G	Pass
5.7	Pipe stiffness	AS/NZS 1462.22	Pass
5.9	Joint separation	Appendix I	Pass

Transport and Main Roads Specification MRTS03

Clause	Requirement	Result
22.2.1	Perforated drainage pipes for Type B subsoil drains	Pass

TfNSW QA 3552

Clause	Requirement	Test method	Result
5.1	Physical properties	T1505	Pass
5.2	Stiffness properties	T1506	Pass

Product Range

Vinidex Code	Nominal Size DN (mm)	Type	SN	Coil Length (m)
24725	100	Slotted with RTA Filtersock	20	100
24751	160	Slotted with RTA Filtersock	20	20
24724	100	Slotted	20	100
24750	160	Slotted	20	20

Vinidex is committed to quality products and systems and is a Quality Endorsed Company to **ISO 9001 "Quality Management Systems – Requirements"**. Certificate No QEC0570.