

16 July 2025

CERTIFICATE OF COMPLIANCE

SN8 (Class 400) Draincoil with Filtersock

Vinidex supplies and manufactures Draincoil to comply with the following requirements of **AS 2439.1 “Perforated plastics drainage and effluent pipe and fittings. Part 1: Perforated drainage pipe and associated fittings”**:

Clause	Requirement	Test method	Result
2.3	Freedom from defects	Visual inspection	Pass
2.4.1	Diameter	Appendix B	Pass
2.4.2	Length	Clause 2.4.2	Pass
3.1	Perforation dimensions and area	Appendix B	Pass
5.7	Pipe stiffness	AS/NZS 1462.22	Pass

Transport and Main Roads (Qld) Specification MRTS03

Clause	Requirement	Result
22.2.1	Perforated drainage pipes for Type B subsoil drains	Pass

TfNSW QA 3552

Clause	Requirement		Test method	Result
5.1	Physical properties		T1505	Pass
5.2	Stiffness properties		T1506	Pass

TfNSW QA R63

Clause	Requirement	Result
2.1	General material requirements	Pass
2.2	Geotextile strength and filtration class requirements	Pass

Product Range

Vinidex Code	Nominal Size DN (mm)	Type	SN	Coil Length (m)
24712	100	Slotted with RTA Filtersock	8	100
24714	100	Slotted with RTA Filtersock	8	50
24746	160	Twin Wall Slotted with RTA Filtersock	8	40

Vinidex is committed to quality products and systems and is a Quality Endorsed Company to **ISO 9001 “Quality Management Systems – Requirements”**. Certificate No QEC0570.



.....
IAN PATERSON
Market Development Engineer