

Our Reference: DM6245686  
Contact Officer: Rodney Betts  
Telephone: 07 4688 6729

29 January 2015

Attention: Ian Paterson  
Market Development Engineer  
Vinidex Pty Ltd  
PO Box 379  
Sunnybank Qld 4109

Email: [ipaterson@vinidex.com.au](mailto:ipaterson@vinidex.com.au)

Dear Ian

## StormPRO Stormwater Pipes

I refer to your enquiries as to Toowoomba Regional Council's position in relation to the use of StormPRO Stormwater pipes for Council Infrastructure.

I wish to advise that following consideration with the General Manager Infrastructure Services, the use of StormPRO Stormwater pipes and other HDPE ribbed pipe products will be permitted for:

1. inter-allotment drainage installation, and
2. other land under Council's control where the slope is greater than 10% and the prior approval of the General Manager Infrastructure Services has been obtained.

Please note the use of StormPRO and other HDPE ribbed pipe products will not be permitted under roads/road reserve under any circumstances.

For your information, these recommendations will be included in the forthcoming review of Toowoomba Regional Council's Regional Planning Scheme Schedule 4 Planning Scheme Policies SC 4.2 – PSP No. 2 Engineering Standards – Roads and Drainage Infrastructure.

Should you have any further queries regarding this matter please call me on 07 4688 6729.

Yours faithfully



Rod Betts  
Manager - Transport and Drainage Planning